

FLOOR AND WALL OPENINGS

- ☐ Are floor openings guarded by a cover, a guardrail, or equivalent on all sides (except at entrance to stairways or ladders)?

Action to be Taken

Assigned To:

- ☐ Are toeboards installed around the edges of permanent floor opening (where persons may pass below the opening)?

Action to be Taken

Assigned To:

- ☐ Are skylight screens or other covers of such construction and mounting that they will withstand a load of at least twice the weight of employees, equipment, and materials that may be imposed?

Action to be Taken

Assigned To:

- ☐ Is the glass in the windows, doors, glass walls, etc., which are subject to human impact, of sufficient thickness and type for the condition of use?

Action to be Taken

Assigned To:

- ☐ Are grates or similar type covers over floor openings such as floor drains of such design that foot traffic or rolling equipment will not be affected by the grate spacing?

Action to be Taken

Assigned To:

- ☐ Are unused portions of service pits and pits not actually in use either covered or protected by guardrails or equivalent?

Action to be Taken

Assigned To:

- ☐ Are manhole covers, trench covers and similar covers, plus their supports designed to carry twice the maximum axle load when located in roadways and subject to vehicle traffic?

Action to be Taken

Assigned To:

- ☐ Are floor or wall openings in fire resistive construction provided with doors or covers compatible with the fire rating of the structure and provided with self closing feature when appropriated?

Action to be Taken

Assigned To:
